

CERTIFICATE OF COMPLIANCE

Certificate Number 20160725-E210412
Report Reference E210412-20160722
Issue Date 2016-JULY-25

Issued to: Digital Electronics Corp
Schneider Electric Osaka Bldg
4-4-9 Kitahama Chuo-Ku
Osaka 541-0041 JAPAN

**This is to certify that
representative samples of**

PROGRAMMABLE CONTROLLERS FOR USE IN
HAZARDOUS LOCATIONS

USL, CNL - Class I, Division 2, Groups A, B, C, and D
Hazardous Locations.

Open-type Human Machine Interface, PFXGP4110 series;
Models PFXGP4114T*D#, PFXGP4115T*D# and
PFXGP4116T*D# ("*" may be any letter or number. "#" may
be any one to three alphanumeric digits.)

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: Standard No. ANSI/ISA 12.12.01-2015 and CAN/CSA
C22.2 No. 213-15 - Approved 21 August 2015,
Nonincendive Electrical Equipment for Use in Class I and II,
Division 2 and Class III, Divisions 1 and 2 Hazardous
(Classified) Locations

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

