# QnA Series CPU Direct Driver

1	System Configuration	3
	Selection of External Device	
3	Example of Communication Setting	5
4	Setup Items	7
5	Cable Diagram	11
6	Supported Device	17
7	Device Code and Address Code	19
8	Error Messages	21

#### Introduction

This manual describes how to connect the Display and the External Device (target PLC). In this manual, the connection procedure will be described by following the below sections:

System Configuration "1 System Configuration" (page 3) This section shows the types of External Device which can be connected and SIO type. Selection of External Device "2 Selection of External Device" (page 4) Select a model (series) of the External Device to be connected and connection method. **Example of Communication Settings** 3 "3 Example of Communication Setting" This section shows setting examples for (page 5) communicating between the Display and the External Device. 4 Setup Items "4 Setup Items" (page 7) This section describes communication setup items on the display. Set communication settings of the Display with GP-Pro Ex or in off-line mode. Cable Diagram 5 "5 Cable Diagram" (page 11) This section shows cables and adapters for connecting the Display and the External Device. Operation

# 1 System Configuration


The system configuration in the case when the External Device of Mitsubishi Electric Corp. and the Display are connected is shown.

Series	CPU	Link I/F	SIO Type	Setting Example	Cable Diagram
MELSEC QnA Series	Q4A CPU Q3A CPU O2A CPU -S1	CPU Direct	RS232C	Setting Example 1 (page 5)	Cable Diagram 1 (page 13)
	Q2A CPU Q2ASH CPU -S1 Q2ASH CPU	Ci o blicci	RS422/485 (4wire)	Setting Example 2 (page 6)	Cable Diagram 2 (page 14)
	Q2AS CPU -S1 Q2AS CPU Q4AR CPU	2-port adapter II by Pro-face *1 (Model: GP070-MD11)	RS422/485 (4wire)	Setting Cable Example 2 Diagram 3 (page 6) (page 15)	Diagram 3

<sup>\*1</sup> Supported by 2-port adapter II Rev. B or later. 2-port adapter II does not support the communication in 38,400. Please use it in 19,200.

## 2 Selection of External Device

Select the External Device to be connected to the Display.



Setup Items	Setup Description	
Maker	Select the maker of the External Device to be connected. Select "Mitsubishi Electric Corporation".	
Driver	Select a model (series) of the External Device to be connected and connection method.  Select " QnA Series CPU Direct".  Check the External Device which can be connected in " QnA Series CPU Direct" in system configuration.  "1 System Configuration" (page 3)	
Use System Area	Check this option when you synchronize the system data area of Display and the device (memory) of External Device. When synchronized, you can use the ladder program of External Device to switch the display or display the window on the display.  Cf. GP-Pro EX Reference Manual "Appendix 1.4 LS Area (only for direct access method)"  This can be also set with GP-Pro EX or in off-line mode of Display.  Cf. GP-Pro EX Reference Manual " 5.14.6 Setting Guide of [System Setting Window]■[Main Unit Settings] Settings Guide System Area Setting"  Cf. Maintenance/Troubleshooting "2.14.1 Settings common to all Display models System Area Settings"	
Port	Select the Display port to be connected to the External Device.	


# 3 Example of Communication Setting

Examples of communication settings of the Display and the External Device, recommended by Pro-face, are shown.

#### 3.1 Setting Example 1

- Setting of GP-Pro EX
- ◆ Communication Settings

To display the setting screen, select [Device/PLC Settings] from [System setting window] in workspace.



#### Settings of External Device


There is no setting on the External Device. The speed automatically switches according to the Display setting.

#### 3.2 Setting Example 2

#### ■ Setting of GP-Pro EX

#### Communication Settings

To display the setting screen, select [Device/PLC Settings] from [System setting window] in workspace.



#### Device Setting

There is no setting on the External Device. The speed automatically switches according to the Display setting.

### 4 Setup Items

Set communication settings of the Display with GP-Pro Ex or in off-line mode of the Display.


The setting of each parameter must be identical to that of External Device.

"3 Example of Communication Setting" (page 5)

#### 4.1 Setup Items in GP-Pro EX

#### ■ Communication Settings

To display the setting screen, select [Device/PLC Settings] from [System setting window] in workspace.



Setup Items	Setup Description		
SIO Type	Select the SIO type to communicate with the External Device.		
Speed	Select speed between the External Device and the Display.		
Data Length	Select data length.		
Parity	Select how to check parity.		
Stop Bit	Select stop bit length.		
Flow Control Select the communication control method to prevent overflow of transmission reception data.			

continued to next page

Setup Items	Setup Description	
Timeout Use an integer from 1 to 127 to enter the time (s) for which the Display waits for the response from the External Device.		
Retry  In case of no response from the External Device, use an integer from 0 to 255 to enter many times the Display retransmits the command.		
Wait To Send  Use an integer from 0 to 255 to enter standby time (ms) for the Display from recepackets to transmitting next commands.		
RI/VCC You can switch RI/VCC of the 9th pin when you select RS232C for SIO type.		

#### 4.2 Settings in Off-Line Mode




- Please refer to Maintenance/Troubleshooting for more information on how to enter off-line mode or about operation.
- Cf. Maintenance/Troubleshooting "2.2 Offline Mode"

#### ■ Communication Settings


To display the setting screen, touch [Device/PLC Settings] from [Peripheral Settings] in off-line mode. Touch the External Device you want to set from the displayed list.

(Page 1/2)



Setup Items	Setup Description	
SIO Type	Select the SIO type to communicate with the External Device.	
Speed	Select speed between the External Device and the Display.	
Data Length	Data length is displayed.	
Parity	The parity check method is displayed.	
Stop Bit	Stop bit length is displayed.	
Flow Control	The communication control method to prevent overflow of transmission and reception data is displayed.	
Timeout (s)	Use an integer from 1 to 127 to enter the time (s) for which the Display waits for the response from the External Device.	
Retry	In case of no response from the External Device, use an integer from 0 to 255 to enter how many times the Display retransmits the command.	
Wait to Send (ms)	Use an integer from 0 to 255 to enter standby time (ms) for the Display from receiving packets to transmitting next commands.	

#### (Page 2/2)



Setup Items	Setup Description	
RI/VCC	You can switch RI/VCC of the 9th pin when you select RS232C for SIO type.	

The cable diagram shown below may be different from the cable diagram recommended by Mitsubishi Electric Corp. Please be assured there is no operational problem in applying the cable diagram shown in this manual.

- The FG pin of the main body of the External Device must be D-class grounded. Please refer to the manual of the External Device for more details.
- SG and FG are connected inside the Display. When connecting SG to the External Device, design the system
  not to form short-circuit loop.
- Connect the isolation unit, when communication is not stabilized under the influence of a noise etc..
- When connecting IPC with External Device by RS-232C, the COM port which can be used changes with series. Please refer to the manual of IPC for details.

Usable port

Series	Usable port
PS-2000B	COM1*1, COM2, COM3*1, COM4
PS-3650A, PS-3651A	COM1*1
PS-3700A (Pentium®4-M)	COM1*1, COM2*1, COM3*2, COM4

<sup>\*1</sup> The RI/5V can be switched. Please switch with the change switch of IPC.

When connecting to the COM3 of PS-3700A (Pentium®4-M) with External Device, it is necessary to set up
the SIO type of COM3 with a Dip switch. Please refer to the manual of PS-3700A (Pentium®4-M) for details.

Dip switch setting: RS-232C

Dip switch	Setting	Description	
1	OFF	Reserve (always OFF)	
2	OFF	SIO type of COM3: RS-232C	
3	OFF	SIO type of COMS. RS-232C	
4	OFF	Output mode of TX data: Always output	
5	OFF	Terminal resistance insertion to TX (220Ω): None	
6	OFF	Terminal resistance insertion to RX (220Ω): None	
7	OFF	Short-circuit of TXA and RXA: Does not Exist	
8	OFF	Short-circuit of TXB and RXB: Does not Exist	
9	OFF	Auto Detection: Disable	
10	OFF		

<sup>\*2</sup> It is necessary to set up the SIO type with the Dip switch.


#### Dip switch setting: RS-422/485 (4 wire)

Dip switch	Setting	Description	
1	OFF	Reserve (always OFF)	
2	ON	SIO type of COM3: RS-422/485	
3	ON	SIO type of COMS. KS-422/463	
4	OFF	Output mode of TX data: Always output	
5	OFF	Terminal resistance insertion to TX (220Ω): None	
6	OFF	Terminal resistance insertion to RX (220Ω): None	
7	OFF	Short-circuit of TXA and RXA: Does not Exist	
8	OFF	Short-circuit of TXB and RXB: Does not Exist	
9	OFF	- Auto Detection: Disable	
10	OFF		

Display (Connection Port)	Cable	Notes
GP (COM1) IPC*1*2	Interface internal cable for Mitsubishi FA equipments by Diatrend Corp.	Available to order the length up to 15 m
	DAFXIH-CABV (3m)	up to 13 m

<sup>\*1</sup> Usable ports are different by the series.

Dip switch setting: RS-232C (page 11)




Usable port (page 11)

<sup>\*2</sup> When use the COM3 of PS -3700A (Pentium®4-M) , set the SIO type of COM3 with Dip switch.


Display (Connection Port)	Cable		Notes
GP*1 (COM1) AGP-3302B (COM2)	A	Mitsubishi A connection cable by Pro-face CA3-CBLA-01 (5m)	
IPC*2 (COM3)	В	Your own cable	The cable length must be 5m or less.

<sup>\*1</sup> All GP models except AGP-3302B

A) When using Mitsubishi A connection cable (CA3-CBLA-01) by Pro-face.



B) When using your own cable



<sup>\*2</sup> Only COM3 of PS -3700A (Pentium®4-M) can be used. When use the COM3, set the SIO type of COM3 with Dip switch.


Dip switch setting: RS-422/485 (4 wire) (page 12)

Display (Connection Port)	Cable	Notes
GP*1 (COM1) AGP-3302B (COM2) IPC*2 (COM3)	A COM port conversion adapter by Pro-face CA3-ADPCOM-01  + 2-port adapter cable for AGP by Pro-face CA3-MDCB11 (5m)  + 2-port adapter II by Pro-face GP070-MD11	
	Your own cable  + 2-port adapter II by Pro-face GP070-MD11	The cable length must be 600m or less.
GP*3 (COM2)	Online adapter by Pro-face CA4-ADPONL-01  + 2-port adapter cable for AGP by Pro-face CA3-MDCB11 (5m)  + 2-port adapter II by Pro-face GP070-MD11	
	Online adapter by Pro-face CA4-ADPONL-01  + Your own cable  + 2-port adapter II by Pro-face GP070-MD11	The cable length must be 600m or less.

<sup>\*1</sup> All GP models except AGP-3302B

Dip switch setting: RS-422/485 (4 wire) (page 12)


A) When using COM port conversion adapter (CA3-ADPCOM-01), 2-port adapter cable for AGP (CA3-MDCB11) by Pro-face and 2-port adapter II (GP070-MD11) by Pro-face




<sup>\*2</sup> Only COM3 of PS -3700A (Pentium®4-M) can be used. When use the COM3, set the SIO type of COM3 with Dip switch.

<sup>\*3</sup> All GP models except GP-3200 series and AGP-3302B


B) When using your own cable and 2-port adapter II (GP070-MD11) by Pro-face.



C) When using online adapter (CA4-ADPONL-01), 2-port adapter cable for AGP (CA3-MDCB11) by Pro-face and 2-port adapter II (GP070-MD11) by Pro-face.



D) When using online adapter (CA4-ADPONL-01) by Pro-face, your own cable and 2-port adapter II (GP070-MD11) by Pro-face.



# 6 Supported Device

Range of supported device address is shown in the table below.

This address can be specified as system data area.

Device	Bit Address Word Address		32 bits	Notes
Input Relay	X0000 - X1FFF	X0000 - X1FF0		<u>***</u> 0]
Output Relay	Y00000 - Y1FFF	Y0000 - Y1FF0		<u>***</u> 0]
Internal Relay	M00000 - M32767	M00000 - M32752		<u>÷16</u> )
Special Relay	SM0000 - SM2047	SM0000 - SM2032		<u>÷16</u> )
Latch Relay	L000000 - L32767	L00000 - L32752		<u>÷16</u> )
Annunciator	F00000 - F32767	F00000 - F32752		<u>÷16</u> )
Edge Relay	V00000 - V32767	V00000 - V32752		<u>÷16</u> )
Step Relay	S0000 - S8191	S0000 - S8176		<u>÷16</u> )
Link Relay	B0000 - B7FFF	B0000 - B7FF0		*** 0]
Special Link Relay	SB000 - SB7FF	SB000 - SB7F0		*** 0]
Timer (Contact)	TS00000 - TS23087			
Timer (Coil)	TC00000 - TC23087		լե / Hj	
Retentive Timer (Contact)	SS00000 - SS23087			
Retentive Timer (Coil)	SC00000 - SC23087			
Counter (Contact)	CS00000 - CS23087			
Counter (Coil)	CC00000 - CC23087			
Timer (Current Value)		TN0000 - TN23087		
Retentive Timer (Current Value)		SN0000 - SN23087		
Counter (Current Value)		CN0000 - CN23087		
Data Register	Register			(B i + F)
Special Register		SD0000 - SD2047	,	
Link Register		W0000 - W657F		<sub>Bit</sub> F)
Special Link Register		SW000 - SW7FF		Bitl

continued to next page

Device	Bit Address Word Address		32 bits	Notes
File Register (Normal)		R00000 - R32767		<u> </u>
File Register (Block switching is not necessary)		ZR0000000 - ZR1042431		[B:+ F] *1
		0R00000 - 0R32767		
		1R00000 - 1R32767		
		2R00000 - 2R32767		
*0		3R00000 - 3R32767	[L/H]	
File Register <sup>*2</sup> (0R - 31R)	:	:		E i t F]*1
(**************************************		28R00000 - 28R32767		
		29R00000 - 29R32767		
		30R00000 - 30R32767		
		31R00000 - 31R26623		

<sup>\*1</sup> You need the memory card when using the file register.

#### NOTE

- Please refer to the GP-Pro EX Reference Manual for system data area.
  - Cf. GP-Pro EX Reference Manual "Appendix 1.4 LS Area (only for direct access method)"
- Please refer to the precautions on manual notation for icons in the table.
  - "Manual Symbols and Terminology"
- Even if you use an address not existing in the External Device, no read error may be displayed. In this case, the read-out data keeps 0. In writing, an error is displayed.

<sup>\*2</sup> Set the block No. on the head of device name. This is the device name for conversion with GP-Pro/PB III for Windows. When you newly specify the device, we recommend that you should use the file register (Block switching is not necessary).

# 7 Device Code and Address Code

Use device code and address code when you select "Device Type & Address" for the address type in data displays.

Device	Device Name	Device Code (HEX)	Address Code
Input Relay	X	0080	Value of word address divided by 0x10
Output Relay	Y	0081	Value of word address divided by 0x10
Internal Relay	M	0082	Value of word address divided by 16
Special Relay	SM	0083	Value of word address divided by 16
Latch Relay	L	0084	Value of word address divided by 16
Annunciator	F	0085	Value of word address divided by 16
Edge Relay	V	0086	Value of word address divided by 16
Step Relay	S	0087	Value of word address divided by 16
Link Relay	В	0088	Value of word address divided by 0x10
Special Link Relay	SB	0089	Value of word address divided by 0x10
Timer (Current Value)	TN	0060	Word Address
Retentive Timer (Current Value)	SN	0062	Word Address
Counter (Current Value)	CN	0061	Word Address
Data Register	D	0000	Word Address
Special Register	SD	0001	Word Address
Link Register	W	0002	Word Address
Special Link Register	SW	0003	Word Address
File Register (Normal)	R	000F	Word Address
File Register (Block switching is not necessary)	ZR	000E	Word Address
	0R	0010	Word Address
	1R	0011	Word Address
	2R	0012	Word Address
	3R	0013	Word Address
File Register (0R - 31R)	:	:	:
, ,	28R	002C	Word Address
	29R	002D	Word Address
	30R	002E	Word Address
	31R	002F	Word Address

# 8 Error Messages

Error messages are displayed on the screen of Display as follows: "No.: Device Name: Error Message (Error Occurrence Area)". Each description is shown below.

Item	Description	
No.	Error No.	
Device Name	Name of External Device where error occurs. Device name is a title of External Device set with GP-Pro EX.(Initial value [PLC1])	
Error Message	Displays messages related to the error which occurs.	
	Displays IP address or device address of External Device where error occurs, or error codes received from External Device.	
Error Occurrence Area	<ul> <li>NOTE</li> <li>IP address is displayed such as "IP address(Decimal): MAC address(Hex)".</li> <li>Device address is diplayed such as "Address: Device address".</li> <li>Received error codes are displayed such as "Decimal[Hex]".</li> </ul>	

Display Examples of Error Messages

"RHAA035: PLC1: Error has been responded for device write command (Error Code: 2 [02])"



- Please refer to the manual of External Device for more detail of received error codes.
- Please refer to "When an error message is displayed (Error code list)" of "Maintenance/ Troubleshooting" for a common error message to the driver.